



CE Declaration of Conformity for microgeneration systems

Product: Ampair 6000
Type: Ampair 6000 – 48 volt micro wind turbine
 Ampair 6000 – 240 volt micro wind turbine
 Ampair 6000 interconnect units including stop switch
 6000 watt grid-tie inverters (Power-one Aurora PVI 6000)
 5000 watt inverters (Power-one Aurora MWI 5000)
 Mounting systems (base hinged monopole towers)

We declare that the above specified devices are compliant with the regulations of the European Community when installed as a system.

The devices are compliant with the relevant parts of the following standards:

- G83/1 and/or G59/1 and/or EN 50438
- BS En 61400 part 2
(designed in compliance with the standard for a Class I turbine)
- BS EN IEC 60335-1
- LV Directive 73/23/EC
- WEEE Directive 2002/96/EC
- RoHS Directive 2002/95/EC
- EMC Directive 89/336/EC
- Machinery Directive 98/37/EC

Note that this declaration of conformity becomes invalid if:

- The devices are installed, modified, complemented, or changed in a manner which has not been permitted in the devices' Installation, Operation & Maintenance Manuals.
- In case of improper usage.

Ampair Energy Ltd
 Unit 2 Milborne Business Centre
 Blandford Hill, Milborne St Andrew
 Blandford Forum
 DT11 0HZ
 UK

Tel +44 (0)1258 837 266
 Fax +44 (0)1258 837 496

www.ampair.com
 info@ampair.com

David Sharman
 Managing Director
 10th February 2011

Date: 2 Aug 2009	Ampair 600 declaration of CE	CD 2920
Issue: 1.0		Page 1 of 1